

Compiled/Updated	LL
Approved	CD
Issued Date	5-6-26
Amendment	A3

Product Data Sheet - Fuse & Link Covers

Covers for covering fuses, links, switches and communication cables where they may affix to the pole.

Key Features:

- Reliable and trusted PVC material.
- Soft and flexible EPDM rubber material.
- Conforms to AS 4202 Class II.
- 650v max use.
- Product has been used in Australian utility sector for decades.
- Dual layer PVC and EPDM safety feature.





Figure 1 Fuse-Link Cover 80XX



Compiled/Updated	LL
Approved	CD
Issued Date	5-6-26
Amendment	A3

Part No. Table (A)

<u>Part Number</u>	<u>Description</u>
8001	Fuse-Link Cover-600x375-Studs-PVC-Y/G-650V
8002	Comms Cable Cover / Drape-600 x 225mm drop PVC Studs Y/G-650V AS4202
8006	Comms Cable Cover / Drape-600x225mm PVC Mag/Studs Y/G-650V AS4202
8007	Fuse Cover-850x850-Plain-PVC-Y/G-650V
8008	Substation Drape-850x850-Mag-PVC-Y/G-650V
8010	Fuse Cover-850x700-Velcro-EPDM-Y/B-650V
8016	Fuse Cover-400x400-Studs-PVC-Y/G-650V
8020	Fuse Cover-600x375-Magnets-PVC-Y/G-650V

Dimensions and Materials Table (B)

Product	X (Length)	Y (Width)	Thickness	Class	Material
8001	600mm	375mm (drop)	2mm	CLASS II	Dual Layer Y/G PVC
8002	600mm	225mm (drop)			
8006	600mm	225mm (drop)			
8007	850mm	850mm			
8008	850mm	850mm			
8010	850mm	700mm			Dual Layer Y/B EPDM

Compiled/Updated	LL
Approved	CD
Issued Date	5-6-26
Amendment	A3

8016	400mm	400mm (drop)	2mm	CLASS II	Dual Layer Y/G PVC
8020	600mm	375mm (drop)			

Note: Any dimensions or weights figures are estimates only

Markings Table (C)

Each Line Cover is marked with:

Standard the unit follows
Class
Voltage Rating
Date Of Manufacture (DOM)
Lot number
Item code

Balmoral Engineering AS 4202 CLASS II 650V MAX DOM 12/24 L-13820 ITEM 2001

(example)

Ratings Table (D)

1	AS4202	Compliant	2	650v	Max use
3	Testing on 120°C heated rod for 1 hour^(a)	No adverse functional effect on unit			

(a) Results obtained at Balmoral Engineering inhouse test lab for reference

Disclaimer: BALMORAL ENGINEERING, ROTAMARKA, TIGER TAILS and BIRDFLAPPA are trademarks owned by Balmoral Engineering Pty Ltd. The information in this document or product specification is believed to be correct as of the date of issue and is subject to change without notice. This document should be read in conjunction with the applicable Instructions For Use (IFU) document. Data within Balmoral Engineering Product Data Sheet (PDS) may be subject to tolerances. These tolerances will be defined within the applicable PDS or made available on request. Results and output data in this data sheet are indicative of lab testing protocols and may vary in field applications or environments. BALMORAL ENGINEERING makes no guarantees, expressed or implied as to the merchantability or fitness for purpose. The products are only to be used and installed by industry certified personnel. If applicable, maximum test speeds should be endured by the Products for a limited time period no greater than those described in the lab protocols. Imperial system units of measure are approximations only and have been converted from the data originally recorded in the metric system. Performance of the device in extreme weather events or harsh environments is not warranted. If BALMORAL ENGINEERING sells any component of a product or kit, we make no representations or guarantees as to the serviceability of the actual product or kit into which the component is being added. Furthermore, it is recommended that any such addition to the kit is done by BALMORAL ENGINEERING. In relation to the Balmoral Engineering Visual Warning series of products, it should be noted that not all visual responses to the device are going to be similar or alike. As such, no guarantees can be given as to the products effectiveness. Given the variety of factors that can affect the use and application of a product, some of which are within the user's knowledge and control, it is essential that the user evaluate the product to determine whether it is fit for a particular purpose and suitable for the user's method of use or application. The purpose of this document is to provide a description of the product and/or guidance to the installation thereof. When installing Balmoral Engineering products, due consideration must be given to the user's training and practice methodologies including any requirements of the entity who owns the infrastructure onto which the BALMORAL ENGINEERING Product is being installed. This must take precedence over any guidance BALMORAL ENGINEERING may provide. Notwithstanding, that all the above guidelines are followed, the ultimate responsibility for installing and maintaining the product correctly is with the end user. BALMORAL ENGINEERING accepts no liability for consequential damage relating to wildfires or bushfires particularly in regard to incorrect installation. As service environments may differ markedly with each application, the level of care required may change and is solely the responsibility of the end user. Any product images displayed are representative only. The above data sheet is provided as an estimate of performance and life and is not a guarantee or warranty. © 2026, All Rights Reserved, Balmoral Engineering Pty Ltd.